


भारत सरकार
केन्द्रीय लोक निर्माण विभाग
विज्ञान भवन मण्डल
नई दिल्ली



कमरा नं० 370, द्वितीय तल, विज्ञान भवन एनेक्सी, मौलाना आजाद रोड, नई दिल्ली-110011
दूरभाष नं० 011-23022111, फ़ैक्स नं० 011-23022323, ई-मेल : deleecvb.cpwd@nic.in

F.No. - 4(30)/EE/VB/PB/2020-21/1486

Dated - 16/07/2020

To,

Shri Rajiv Mohan Lakhera
Principal, Kendriya Vidyalaya
NFC, Vigyan Vihar, Near Vivek Vihar Police Station,
Delhi - 110092

Sub:- Building Safety Certificate of Kendriya Vidyalaya Building, Vigyan Vihar, Delhi.


Ref:- Your Letter No. F. No. K.V.NFC/V.V./647 Dated 24.02.2020.


Sir,

Kindly refer to your above cited letter vide which you have requested this office for providing structural safety certificate of the above building.

The buildings under the campus Kendriya Vidyalaya, NFC were inspected by Sh. Kanti Prasad, AE (C) along with Sh. Himanshu Gupta, JE (C) of this Division on 16th March, 2020 and **found to be structurally sound and safe.** However, during inspection some minor cracks in parapet walls of Primary, Secondary and Office Block were found. Further, RCC roof shades near Science & Secondary block also needs to be repaired. Regular maintenance works also need to be carried out to avoid seepage at roof, toilets etc.

The structural safety certificate is being issued at your specific request without any liability to CPWD whatsoever.


के.वि.एन.एफ.सी विज्ञान विहार
(द्वितीय पाली)


Executive Engineer,
Vigyan Bhawan, CPWD,
Vigyan Bhawan Annexe, New Delhi